

## NOTICE OF PUBLIC HEARING

CARSON CITY HOLDING, LLC, IS REQUESTING A VARIANCE, #694, FROM THE NEVADA STATE BOARD OF HEALTH REGULATIONS

NOTICE IS HEREBY GIVEN that Carson City Holding, LLC, has requested a variance from Nevada Administrative Code (NAC) 444.178 (Disinfectants: Approval of use of chemical feeders and other disinfecting materials and methods). A public hearing will be conducted on September 7, 2018 at 9:00 am, by the Nevada State Board of Health to consider this request as follows:

Division of Public and Behavioral Health  
4150 Technology Way, Suite 303  
Carson City, Nevada  
Southern Nevada Health District  
280 S. Decatur Blvd  
Red Rock Conference Room  
Las Vegas, NV 89107  
Washoe County

NAC 444.178 states: *"1) A public bathing or swimming facility must be equipped with a chlorinator, hypochlorinator or other disinfectant feeder. Except as otherwise provided in subsections 2 and 3, chemical feeders and process equipment, other than compressed chlorine gas feeders, must be designated by the NSF International as complying with all applicable requirements of Standard 50, "Circulation System Components and Related Materials for Swimming Pools, Spas/Hot Tubs," of the NSF International or in the absence of applicable requirements, be approved by the health authority. A copy of this standard may be obtained from the NSF International, P.O. Box 130140, Ann Arbor, Michigan 48113, at a cost of \$45. 2) The health authority may approve other feeders if the operator of the facility demonstrates to the health authority that the required residual concentrations of disinfectant can be maintained using the feeder. 3) Chemical feeders must be capable of supplying not less than the equivalent of 3 pounds (1.4 kilograms) of chlorine for outdoor pools, or 1 pound (454 grams) of chlorine in the case of an indoor facility, per 10,000 gallons (37,850 liters) of facility capacity during a 24-hour period. 4) The health authority may approve other disinfecting materials or methods if the operator of the facility demonstrates to the satisfaction of the health authority that they provide a satisfactory residual effect which is easily measured and are as effective at disinfecting as the use of the chlorine concentrations required in [NAC 444.148](#). 5) Disinfectant feeders must be installed to ensure that the flow of the chemical disinfectant will stop immediately if there is an interruption in the flow of water to the pool or through the disinfection system."*

Persons wishing to comment upon the proposed variance may appear at the scheduled public hearing or may submit written testimony at least five days before the scheduled hearing to:

Secretary, State Board of Health  
Division of Public and Behavioral Health  
4150 Technology Way, Suite 300  
Carson City, NV 89706

Anyone wishing to testify for more than five minutes on the proposed variance must petition the Board of Health at the above address. Petitions shall contain the following: 1) a concise statement of the subject(s) on which the petitioner will present testimony; 2) the estimated time for the petitioner's presentation.

This notice has also been posted at the following locations:  
DIVISION OF PUBLIC AND BEHAVIORAL HEALTH, 4150 TECHNOLOGY WAY LOBBY, CARSON CITY  
DIVISION OF PUBLIC AND BEHAVIORAL HEALTH WEBSITE: [dpbh.nv.gov](http://dpbh.nv.gov)