

# NOTICE OF PUBLIC HEARING

CANTERBURY HOMES LLC IS REQUESTING A VARIANCE, #703, FROM THE NEVADA STATE BOARD OF HEALTH REGULATIONS.

NOTICE IS HEREBY GIVEN that Canterbury Homes LLC has requested a variance from Nevada Administrative Code (NAC) 444.790 and 444.792. A public hearing will be conducted on June 7, 2019 at 9:00 am, by the Nevada State Board of Health to consider this request as follows:

Division of Public and Behavioral Health  
4150 Technology Way, Suite 303  
Carson City, NV 89706

Grant Sawyer Building  
Room 5100  
555 E. Washington Ave.  
Las Vegas, NV 89101

**NAC 444.790 (1) states:**

1. A minimum area of 1 acre (43,560 square feet), including public streets and alleys or other public rights-of-way, lands or any portion thereof abutting on, running through or within a building site, is required for the installation of an individual sewage disposal system on a lot served by a well.

**NAC 444.792 (2) states:**

2. The minimum horizontal separations that must be maintained between the perimeter of the components of an individual sewage disposal system and the following features are:

Minimum horizontal distance, in clear, required from:	Septic tank	Disposal field (shallow)
Water supply wells (sealed to 50 feet)	100'	100'
Water supply wells (not sealed to 50 feet)	100'	150'

Persons wishing to comment upon the proposed variance may appear at the scheduled public hearing or may submit written testimony at least five days before the scheduled hearing to:

Secretary, State Board of Health  
Division of Public and Behavioral Health  
4150 Technology Way, Suite 300  
Carson City, NV 89706

Anyone wishing to testify for more than five minutes on the proposed variance must petition the Board of Health at the above address. Petitions shall contain the following: 1) a concise

statement of the subject(s) on which the petitioner will present testimony; 2) the estimated time for the petitioner's presentation.

This notice has also been posted at the following locations:

DIVISION OF PUBLIC AND BEHAVIORAL HEALTH, 4150 TECHNOLOGY WAY, CARSON CITY, NV

DIVISION OF PUBLIC AND BEHAVIORAL HEALTH WEBSITE: <http://dpbh.nv.gov>